

ADDENDUM #2

PROJECT 2017-NC-005

Nelson County Fairgrounds

SAMUELS HALL RENOVATION

Located

At

2391 New Haven Road
Bardstown, KY 40004

The following additions/clarifications shall be added to the requirements for Project 2017-NC-005. Any addition costs associated within Addendum #1 shall be included in the Lump Sum Bid. Bidders must acknowledge receipt of this addendum in bid package. The Bid opening time and Date had not changed.

- 1. Addendum: Gutters on each side of building are to be minimum 26 gauge steel.**
- 2. Addendum: The electrical outlets in the main room shall be extended out with Bell box extension rings or approved equal.**
- 3. Addendum: 4 Can lights shall be installed under front porch with switch installed inside adjacent to front door. Lights shall be 6" Can LED soft white lights.**